



Erath County 911 Addressing
1195 W South Loop
Stephenville, TX 76401
Phone (254) 965-0819 Fax (254) 965-5633

Date: October 18, 2024

This is your official notice of your 9-1-1 address. Your address is:

LUGO CINDY

1155 COUNTY ROAD 164

STEPHENVILLE, TX 76401

Legal: A0363 HARPER GEORGE W

Acres: 12.00

Property ID **R77821**

Note: NEW HOUSE

This address may be used to obtain telephone & utility services. For emergency personnel to locate you, the address must be displayed visibly near your entrance with numbers at least 4 inches in size.

Please take this letter to the local post office for the address to be entered in the postal system.

The address is based on the current approved driveway location. **If a new driveway is established at any time in the future, please notify our office so that a new address can be provided. If it is determined that the driveway location presented at the time of addressing does not co-inside with the actual physical location of the driveway per the new aerial, you will be notified of an address change.**

C.L.
(Initials)

Google and other 3rd party mapping systems are not maintained by the Erath County 911 Addressing Dept. As a result, address point locations may not always be accurate on their systems.

Sincerely,

A handwritten signature in cursive script, appearing to read "Lisa Chubb".

9-1-1 Addressing Department

Cindy Lugo
Received By (Print)

[Signature]
Signature

STATE OF TEXAS WELL REPORT for Tracking #680574

Owner:	Cindy Lugo	Owner Well #:	No Data
Address:	1830 Diamond Oaks Rd Stephenville, TX 76401	Grid #:	31-47-5
Well Location:	TBD CR 164 Stephenville, TX 76401	Latitude:	32° 18' 45.04" N
Well County:	Erath	Longitude:	098° 11' 21.03" W
		Elevation:	No Data
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: **10/16/2024** Drilling End Date: **10/16/2024**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	7.875	0	360

Drilling Method: **Air Rotary**

Borehole Completion: **Filter Packed**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Filter Material</i>	<i>Size</i>
Filter Pack Intervals:	210	360	Gravel	.25

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>
Annular Seal Data:	0	3	Cement 1 Bags/Sacks
	3	210	Grout 11 Bags/Sacks

Seal Method: **Pumped**

Sealed By: **Driller**

Distance to Property Line (ft.): **75+**

Distance to Septic Field or other
concentrated contamination (ft.): **110+**

Distance to Septic Tank (ft.): **65+**

Method of Verification: **sight**

Surface Completion: **Surface Sleeve Installed**

Surface Completion by Driller

Water Level:	205 ft. below land surface, and 0 GPM artesian flow on 2024-10-16	Measurement Method:	Air Line
--------------	--	---------------------	-----------------

Packers: **No Data**

Type of Pump: **Submersible**

Well Tests: **Jetted** **Yield: 80 GPM with 65 ft. drawdown after 1 hours**

	<i>Strata Depth (ft.)</i>	<i>Water Type</i>
Water Quality:	274 - 342	Trinity

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **Dowell Well Service**
PO Box 402
Stephenville, TX

Driller Name: **Justin Dowell** License Number: **56066**

Comments: **No Data**

Lithology:
DESCRIPTION & COLOR OF FORMATION MATERIAL

<i>Top (ft.)</i>	<i>Bottom (ft.)</i>	<i>Description</i>
0	32	tan sandy clay
32	128	grey shale and limestone
128	163	blue sandy clay
163	194	sand, sandstone, and gravel
194	210	blue sandy clay
210	255	sand, sandstone, and gravel
255	274	blue and red clay
274	342	sand, sandstone, and gravel
342	360	red and tan clay

Casing:
BLANK PIPE & WELL SCREEN DATA

<i>Dia (in.)</i>	<i>Type</i>	<i>Material</i>	<i>Sch./Gage</i>	<i>Top (ft.)</i>	<i>Bottom (ft.)</i>
4.5	Blank	New Plastic (PVC)	sdr 17	0	360
4.5	Screen	New Plastic (PVC)	sdr 17 0.020	300	360

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540