

WELD COUNTY HEALTH DEPARTMENT

1516 Hospital Road
Greeley, Colorado
Ph. 353-0540

7680 26
PERMIT NO.

Application for permit to Install, Construct, an Individual Sewage Disposal System

Owner TOWNS, Roy Address 3363 LOWELL LN, FERRIS Phone APP-8813

Direction to site: Hwy 7 & I-25 Rd. 3363 LOWELL LN N. mi., E. mi., S. mi., W. mi. 1/2 mi. N.6

Legal Description: Ptn W/4 NE/4 Sec. 33, T. 1N, R. 8W Subdiv. Ranch Eggs Lot 6 Blk 4
Lowell Lane - bet Johnson & Broadway Felling # 2

General Information

No. Bedrooms 4 No. Persons 5
No. Baths 2 Basement Plumbing yes (ump)
Size of Lot 330' x 606.33'
H₂O supply (if well give depth) No Aquifer Water Dist
New Home Mobile Home Modular Add'n
Type of sewage disposal requested:
Septic tank Privy Other

Dept. Use Only
Perc. Rate (Avg. of 3) 1 INCH 15 MIN
Soil Type FINE SAND SILT
H₂O Table Depth 530
Lot Grade 30
Requires Engineer Design Yes No
If yes — reason _____
Comments: _____

Installation Instructions: (Minimum Requirements)

Septic Tank 1250 Gals. Absorption Trenches 800 Sq. Ft.
Other _____ or Seepage bed 1040 Sq. Ft.
Special Instructions _____

This system will be constructed and installed in accordance with the above specifications and regulations regarding individual sewage disposal systems in Weld County, Colorado
This permit shall expire at the same time as the building permit, or, if no building permit is issued, the permit shall expire 120 days after its issuance, if construction has not been commenced.

Date: February 17-1976 Owner: X Roy & Joanne Applicant: _____

The plans and specifications as shown are approved pending payment of permit fee.



Date: 2/24/76
Sanitarian: Bonnie Thelbertson

The above system inspected and found to comply with plan and description.
Systems Contractor: OWNER Date: 2/24/76
Sanitarian: Bonnie Thelbertson

Engineer Review: _____ (Date) _____ (Signature)

Permit Fee: \$ 25.00

Received by: Helene Utah Date: 2-17-76



$$\frac{65}{30} = 1950 \text{ sq. ft.}$$