COLORADO
Division of Water Resources
Department of Natural Resources

FORM 3.1/3.2 WELL MEASUREMENT VERIFICATION FORM-VER. 02/15/21

http://water.state.co.us/groundwater/GWAdmin/UseAndMeasurement

REASON FOR VERIFICATION (CHOOSE ONLY ONE) ■ Verify TFM (3.1) ☐ Re-seal TFM (3.1) ☐ Verify PCC (3.2)

METER LOCATION AND ASSOCIATED WELL INFORMATION: Well Description SE33-5S49W PERMIT# 13256-FP

WDID 1: 4905690 WDID 2: WDID 3: WDID 4:

TAMPER RESISTANT SEAL INFORMATION

Meter Seal No.: 2470233 New Seal No.: Other: Seal No. New Seal No.

Register Seal No.: New Seal No.: Other: Seal No. New Seal No.

REPLACEMENT OF EXISTING TFM (TFM ONLY): Date New TFM Installed: Date Previous TFM Removed:

Removed Meter Serial No: Removed Register Serial No.: Prev. TFM: ☐ Reading ☐ Estimate

NEW METER INFORMATION

Manufacturer: Model: Multiplier: No. Digits: Initial TFM Reading:

INSTALLED TFM (TFM ONLY) Units: ■ Ac-Ft ☐ Gal ☐ Ac-In ☐ Cu-Ft

Meter Serial No: 09-8-1486 Register Serial No.: K-Factor (if adjusted):

TEST METER LOCATION AND DISCHARGE PIPE INFORMATION: OD: 8.700 " Wall Thickness: 0.104 " ID: 8.492 "

TEST METER (COLLINS TUBE): ☐ Standard ☐ Overhung

GPM Factor: Stop Clamp Settings:

	1	2	3	4	5	6	7	8	9	10
Front:										
Back:										
	2-Point		2-Point		2-Point		10-Point			
Avg. of F/B:										

Avg. Collins: x GPM factor

Avg. QT (gpm): **(0,000.0)**

INSTALLED FLOW METER (TFM ONLY)

	Totalizer Readings Acft	Elapsed Time (min:sec)	Instantaneous (gpm) (Min. 10)	
			56	
Stop:	730.3970	15 : 28.00	55	
Start:	730.3650	0 : 0.00	56	
Total:	0.0320	15.47 (Dec. Min.)	56	
			55	
	674.0	**Avg. QI (gpm) (0,000.0)**		

TEST METER (VOLUMETRIC OR ULTRASONIC)

	Reading (gal)	Elapsed Time (min:sec)		
			Spacer Setting:	5.944
			Scale Factor:	1
Stop:	10,226.0	15 : 0.00	Test Material:	Steel
Start:	0.0	0 : 0.00	**Avg. QT (gpm) (0,000.0)**	681.7
Total:	10,226.0	15.00 (Dec. Min.)		

CALIBRATION COEFFICIENT (TFM ONLY)

QT= 681.7 / QI= 674.0 = 1.011 (to 0.000)

For CC greater than 1.050 or less than 0.950, Owner/Agent is REQUIRED to complete Owner/Agent Info and Variance Request.

STABILIZATION (PCC ONLY)

	Time (24:00)	Pumping Level or Discharge Rate (ft)	(gpm)	Pressure (psi)
1	:			
2	:			
3	:			
4	:			
5	:			

DETERMINATION OF PD AND PCC (PCC ONLY)

No. Revs.	Time (sec)	Rate (rev/sec)	Avg. Rate (0.0000)
1			
2			
3			Pt:
4			Ct:
5			Kh:

PD=Avg.Rate x 3.6 x Pt x Ct x Kh= kW (to 0.00)

PCC = (5433 x PD) ÷ (QT) = kWh/af (to 0.0)

Sprinkler End Gun: ☐ On ☐ Off ☐ None

OWNER/AGENT VARIANCE REQUEST (IF REQUIRED)

As Owner or Owner Agent, I hereby request a variance to Measurement Rules for use of a Correction Coefficient or Power Conversion Coefficient as represented on this test. I understand that this Coefficient (TFM or PCC) will be utilized to calculate diversions associated with this meter.

Requester Name:

POWER METER INFORMATION (PCC ONLY):

Serial No. Reading

Power Company YW Electric Multiplier:

USER CONTACT: Name/Entity: Prosper Farms, LLC Phone No.: 303-594-0740

TESTER STATEMENT: I hereby state that I am currently a person approved by the State Engineer to conduct well tests pursuant to the appropriate Rules Governing the Measurement of Ground Water Diversions. I have personally conducted measurement verification (TFM or PCC) of the above-described measurement device as required by the Rules/Program Standard. I understand that falsifying this test can subject me to a fine of up to $500.

Tester Name: Rod Mason-Quality Irrigation Date of Well Test: 04/10/2025 Test Meter Serial No.: N6H1755T

COLORADO
Division of Water Resources
Department of Natural Resources

COMMENTS:

One well services one sprinkler. The circle was planted to wheat.







