

Other Options

[Return to menu](#)
[Plot this site in State Library Digital Atlas](#)
[Plot this site in Google Maps](#)

Section 7: Well Test Data

Total Depth: 380
Static Water Level: 44
Water Temperature:

18 gpm with drill stem set at 360 feet for 1 hours.
Time of recovery 1 hours.
Recovery water level 44 feet.
Pumping water level feet.

** During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.*

Section 8: Remarks

Section 9: Well Log

Geologic Source

Unassigned

[illegible]

Date well completed: Wednesday, June 24, 2026

Borehole dimensions

Casing

From	To	Diameter	Wall Thickness	Pressure Rating	Joint	Type
------	----	----------	----------------	-----------------	-------	------

-2	80	6	0.25		WELDED	A53B STEEL
20	360	4			SPLINE	ABS- SCHED 40

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name: WILLIAM (JOE) DAVIS

Company: DAVIS BROTHERS DRILLING

License
No: WWC-651

Date
Completed: 6/24/2026

Completion (Perf/Screen)

From	To	Diameter	# of Openings	Size of Openings	Description
320	360	4	24	1/16X6	SAW SLOTS

Annular Space (Seal/Grout/Packer)

From	To	Description	Cont. Fed?
0	40	WYO-BEN # 8	Y