


Lance Jaresh
481 O'Hanlon Rd
Whitesboro, Tx 76273
903-815-4951
lancejaresh@gmail.com

TCEQ Site Evaluator 32471
Registered Sanitarian 4788



Site Evaluation

Date: 12/16/2020

Applicant: Marcus Athey
Phone Number: 469-569-4201
Mailing address:
Site Address: 423 Briar Creek Whiteboro
Land Plot Size: 10.02 acres

Hole #	Hole Depth	Soil Description	USDA Soil Class
1-2	0-24"	Sandy Loam	II
1-2	24-60"	Sandy Clay Loam	III

Comments: Class the soil suitable for a standard system

100 Flood zone	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	ossf o/s flood zone
Evidence of ground water	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Disposal Conflicts	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Set-Back Conflicts	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Restrictive Horizons	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Well	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	

Topography: 2-3%

Comments: 3br <4500 sq ft- $Q=360 \text{ gpd}$ $360/.2 = 1800 \text{ sq ft}$ $1800/5 = 360 \text{ linear ft}$ of 3' wide lateral lines.

Install ~~1500 gal 2 compartment~~ tank and 370' of 3 ft wide lateral lines

-2-750gal

Texas Site Evaluator (TCEQ) # 32471

Lance Jaresh RS



GRAYSON COUNTY OSSF PROGRAM APPLICATION
100 W. HOUSTON ST. - SUITE G1
SHERMAN, TX 75090
(903) 813-4253 Fax: (903) 813-1412

1. PROPERTY OWNER'S NAME: Marcus Athey & Bonnie Athey
2. CURRENT MAILING ADDRESS: 204 Second St, Whitesboro TX 76273
3. DAYTIME PHONE NO: 469-569-4201 ALT. NO: 469-500-3566
4. 911 SITE ADDRESS: 423 Briar Creek, Whitesboro TX 76273
PROPERTY ID #: R322784 229927
5. LEGAL DESCRIPTION: Sec. _____ Block _____ Lot 10 Plat Date: _____
SUBDIVISION NAME: Briar Creek VOL. /PG: _____
OTHER THAN SUBDIVISION: Acreage: 100.2 Survey Name: _____
Date Purchased: _____
6. SOURCE OF WATER: ___ private well ☒ Public Water Supply Two Way SUD
* Do you have water savings devices: yes or no (Name of Supplier) _____
7. SINGLE FAMILY RESIDENCE: No. of Bedrooms: 3 Living Area (sq. ft) 3531
No. of Occupants: 4
8. COMMERCIAL/ INSTITUTIONAL (including multi-family residences) TYPE: _____
NO. OF EMPLOYEES/OCCUPANTS/UNITS: _____ DAYS OCCUPIED PER WEEK: _____
9. SITE EVALUATOR: Lance Jansh LICENSE NO: 32471
PHONE NO: 903-815-4951
10. INSTALLER: Lance Jansh LICENSE NO: 32313
PHONE NO: 903-815-4951
11. REGISTERED SANITARIAN: Lance Jansh LICENSE NO: 4788
PHONE NO: 903-815-4951

I certify that the above statements are true and correct to the best of my knowledge. Authorization is hereby given to Grayson County and their agents or designees to enter upon the above described property for the purpose of inspection of the On-site Sewage Facility. I also understand that I must apply for a new 911 address for each new installation.

[Signature]
(Signature of Owner)

12/10/20
(Date)

For Office Use Only:

OSSF PERMIT NUMBER: _____

DATE RECEIVED: _____

AEROBIC _____ AFFID FILED _____

STANDARD _____ CONTRACT _____

Grayson CAD Web Map



12/16/2020, 11:23:00 AM

- Flood Hazard Zones
- 1% Annual Chance Flood Hazard
- Regulatory Floodway
- Special Floodway
- Area of Undetermined Flood Hazard
- 0.2% Annual Chance Flood Hazard

Disclaimer: This product is for informational purposes only and does not constitute a professional engineering or surveying examination. It does not represent an actual ground survey and represents only the data on which the product was created. The location of boundaries is not guaranteed.



GRAYSON COUNTY OSSF PROGRAM
100 W. HOUSTON ST - STE. G1
SHERMAN, TX 75090
(903) 813-4253

AUTHORIZATION AGENT: *GRAYSON COUNTY*

**AUTHORIZATION TO CONSTRUCT AN
ON-SITE SEWAGE FACILITY**

Permit No: 2020-655

Property Owner: Marcus Athey

Property Location: 423 Briar Creek
Whitesboro, TX 76273
Grayson County, Texas

Final: _____

This serves to notify all persons that the on-site sewage facility applications, related technical data, and the appropriate fee have been received by Grayson County from the property owner. The application has been reviewed for technical and administrative consideration against the standards set forth by TCEQ. Approval is hereby granted for the construction as shown on the submitted plans.

Any modifications to submitted plans require approval by the authorized Agent prior to installation.

You or your installer must contact the approving GRAYSON COUNTY AGENT five (5) working days prior to completion to arrange the required facility inspection. The authorization to construct is valid for one year from the date of issuance. If a final inspection has not been performed within one year of issuance, a new application and fee will be required.

Application reviewed by:


Liz Huffman

DR# OS 0035680

12/17/2020

Designated Representative for
Grayson County

Date



3 br
3531 sq ft


423 Briar Creek
Whitesboro

120' 7"

750 gal
tanks

X = bore holes

Electric line



Flood plain



[Signature]
1/30/21

0 50 250ft