

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SZ317		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BENNETT, BRUCE						Phone # (608)238-4543		1. Well Location				Fire # (if avail.)					
Mailing Address 2914 ARBOR DR						Town of MARION						6050					
City MADISON						State WI		Zip Code 53711				Street Address or Road Name and Number					
County Grant						Co. Permit #		Notification # 19940364		Completed 07-05-2005		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) CORPIAN WELL DRILLING INC						Lic. # 61		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0597 °N -90.7342 °W		Method Code GCD013			
Address 4747 OLD C RD BOSCOBEL WI 53805						Well Plan Approval #		NE NE		Section 28		Township 7 N		Range 3 W			
Hicap Permanent Well #						Common Well #		Specific Capacity 0.1				2. Well Type New Well					
3. Well serves # of CAMPERS						Hicap Well ? No		of previous unique well #				constructed in					
Private, potable						Hicap Property ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled					
Heat Exchange ___ # of drillholes						Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
10		Surface		210		Rotary - Mud Circulation											
6		210		420		<u>Yes</u> Rotary - Air <u>No</u> <u>Yes</u> Rotary - Air & Foam <u>Yes</u>											
Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)																	
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)							
- - I -		DIRT						Surface		6							
- - L -		LIMEROCK						6		38							
- - N -		SANDROCK						38		96							
- C L -		LIMEROCK & CREV						96		203							
- - L -		LIMEROCK						203		296							
- H H -		HARD SHALE						296		420							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level							
6		NEW BLACK STEEL PLAIN END WHEATLAND ASTMA53B 6X21 #18.97				Surface		210		286 ft. below ground surface							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is							
										12 in. above grade							
7. Grout or Other Sealing Material										10. Pump Test							
Method TREMIE PUMPED										Pumping level 405 ft. below surface							
Kind of Sealing Material										Pumping at 10 GP M for 2 Hrs.							
NEAT CEMENT										Pumping Method ?							
From (ft.) Surface To (ft.) 210 # Sacks Cement 73 S										Filled & Sealed Well(s) as needed? Yes							
										NONE							
13. Constructor / Supervisory Driller										Lic #		Date Signed					
SAA												07-05-2005					
Drill Rig Operator										Lic or Reg #		Date Signed					
SAA												07-05-2005					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 07-27-2005

Updated On: 03-17-2020

Review Status: